

*Disclaimer* - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the written requirements issued by the NSW Environment Protection Authority. To the best of Kimbriki Environmental Enterprises' knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior written consent from Kimbriki Environmental Enterprises. For more details on publication of pollution monitoring data please refer to the NSW EPA Website, [www.epa.nsw.gov.au](http://www.epa.nsw.gov.au)

Monitoring Period	Apr-18						
Date Published	16 May 2018						
EPA Licence No.	13091						
EPA Licence Hyperlink	<a href="http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=71945&amp;SYSUID=1&amp;LICID=13091">http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=71945&amp;SYSUID=1&amp;LICID=13091</a>						
Licensee Name	KIMBRIKI ENVIRONMENTAL ENTERPRISES PTY LIMITED						
Licensee Address	PO BOX 196, Terrey Hills, NSW 2084						
Monitoring Location (EPA Point 1)	Please refer to the map, <i>Kimbriki Monitoring Sites.pdf</i> , for location (EPA 1)						
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Max. value	100 percentile limit	Exceedance (yes/no)
Explanatory Notes	No surface water discharge occurred from this monitoring point during the month.						
Monitoring Location (EPA Point 2)	Please refer to the map, <i>Kimbriki Monitoring Sites.pdf</i> , for location (EPA 2)						
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Max. value	100 percentile limit	Exceedance (yes/no)
Explanatory Notes	No surface water discharge occurred from this monitoring point during the month.						
Monitoring Location (EPA Point 3)	Please refer to the map, <i>Kimbriki Monitoring Sites.pdf</i> , for location (EPA 3)						
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Max. value	100 percentile limit	Exceedance (yes/no)
Biochemical oxygen demand	mg/L (Note 1)	Special Frequency 1 (Note 2)	1	<5	<5	20	no
Nitrogen (ammonia)	mg/L (Note 1)	Daily during any discharge	1	0.48	0.48	1	no
pH	pH	Daily during any discharge	1	7.60	7.60	6.5-8.5	no
Total suspended solids	mg/L (Note 1)	Daily during any discharge	1	2.60	2.60	50	no
Explanatory Notes	(Note 1) mg/L (milligrams per litre) (Note 2) Special Frequency 1 - Quarterly and on the first day of discharge						

## Monthly Summary of EPA Monitoring Data with Limits

Monitoring Location (EPA Point 21)		Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 21)					
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Max. value	100 percentile limit	Exceedance (yes/no)
Biochemical oxygen demand	mg/L (Note 1)	Special Frequency 1 (Note 2)	2	<5	<5	20	no
Nitrogen (ammonia)	mg/L (Note 1)	Daily during any discharge	4	0.16	1.40	1	Yes
pH	pH	Daily during any discharge	4	7.25	7.52	6.5-8.5	No
Total suspended solids	mg/L (Note 1)	Daily during any discharge	4	2.70	6.90	50	no
Explanatory Notes	(Note 1) mg/L (milligrams per litre) (Note 2) Special Frequency 1 - Quarterly and on the first day of discharge						
Monitoring Location (EPA Point 22)		Enclosed Ground Level Flare in the North-Eastern corner of the Premises. Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 22)					
Parameter	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Max. value	Lower Limit (Note 2)	Exceedance (yes/no)
Residence Time	seconds	Continuous	Continuous	0.9	0.9	0.6	No
Temperature	°C (Note 1)	Continuous	Continuous	787.8	831.9	760	No
Explanatory Notes	(Note 1) °C (degrees Celsius) (Note 2) The parameter value must <b>be greater than</b> the Lower Limit specified						

*Disclaimer* - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the written requirements issued by the NSW Environment Protection Authority. To the best of Kimbriki Environmental Enterprises' knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior written consent from Kimbriki Environmental Enterprises. For more details on publication of pollution monitoring data please refer to the NSW EPA Website, [www.epa.nsw.gov.au](http://www.epa.nsw.gov.au)

Monitoring Period	Apr-18					
Date Published	16 May 2018					
EPA Licence No.	13091					
EPA Licence Hyperlink	<a href="http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=71945&amp;SYSUID=1&amp;LICID=13091">http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=71945&amp;SYSUID=1&amp;LICID=13091</a>					
Licensee Name	KIMBRIKI ENVIRONMENTAL ENTERPRISES PTY LIMITED					
Licensee Address	PO BOX 196, Terrey Hills, NSW 2084					
Monitoring Location (EPA Point 21)	<i>Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 21)</i>					
Pollutant	Units of measure	Monitoring frequency required by licence	100 percentile limit	Exceedance Date	Value	Five-day cumulative rainfall recorded on site (mm) (Note 1)
Nitrogen (ammonia)	mg/L	Daily during any discharge	1	23/04/2018	1.4	0.00
Explanatory Notes	(Note 1) mm (millimetres) (Note 2) The result on 23rd April 2018 was unexpected as on-site testing indicated a result well below 1mg/L (0.56mg/L). The correlation between on-site and laboratory results for the day before and after this event were accurate at 0.5mg/L to 0.8mg/L so it is unclear why this result occurred but is potentially due to sample cross-contamination or other laboratory error.					

*Disclaimer* - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the written requirements issued by the NSW Environment Protection Authority. To the best of Kimbriki Environmental Enterprises' knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior written consent from Kimbriki Environmental Enterprises. For more details on publication of pollution monitoring data please refer to the NSW EPA Website, [www.epa.nsw.gov.au](http://www.epa.nsw.gov.au)

Monitoring Period	Apr-18						
Date Published	16 May 2018						
EPA Licence No.	13091						
EPA Licence Hyperlink	<a href="http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=71945&amp;SYSUID=1&amp;LICID=13091">http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=71945&amp;SYSUID=1&amp;LICID=13091</a>						
Licensee Name	KIMBRIKI ENVIRONMENTAL ENTERPRISES PTY LIMITED						
Licensee Address	PO BOX 196, Terrey Hills, NSW 2084						
Monitoring Location (EPA Point 1)		Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 1)					
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Median value	Max. value
Explanatory Notes		No surface water discharge occurred from this monitoring point during the month.					
Monitoring Location (EPA Point 2)		Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 2)					
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Median value	Max. value
Explanatory Notes		No surface water discharge occurred from this monitoring point during the month.					
Monitoring Location (EPA Point 3)		Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 3)					
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Median value	Max. value
Conductivity	µS/cm (Note 1)	Daily during any discharge	1	490	490	490	490
Explanatory Notes		(Note 1) µS/cm (microsiemens per centimetre)					
Monitoring Location (EPA Point 21)		Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 21)					
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Median value	Max. value
Conductivity	µS/cm (Note 1)	Daily during any discharge	4	428	454	442	502
Explanatory Notes		(Note 1) µS/cm (microsiemens per centimetre)					

## Monthly Summary of EPA Monitoring Data - No Limit

Monitoring Location (EPA Point 22)		<i>Enclosed Ground Level Flare in the North-Eastern corner of the Premises. Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 22)</i>					
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Median value	Max. value
Volumetric flowrate	m <sup>3</sup> /h (Note 1)	Continuous	Continuous	0 (Note 2)	389	404	419
Explanatory Notes	(Note 1) m <sup>3</sup> /h (cubic metres per hour) (Note 2) Zero value due to: 1. Flare was shutdown for 123.0 hours on 5th April 2018 due to power supply outage. Power supply unit had failed and was replaced. Flare restarted after new power supply was installed. 2. Flare was shutdown for 8.5 hours on 15th April 2018 due to power supply outage. 3. Flare was shutdown for 5.0 hours on 16th April 2018 due to power supply outage. 4. Flare was shutdown for 3.5 hours on 17th April 2018 for contractor maintenance which involved checking the pipe fittings of the new blower.						